



Monitor[®]

Mobile Application Flow V1.2.1



Application Name: ecMonitor ACK



The iOS version is expected to be available in February this year.



- The list begins with the latest alert.
- The list will be updated every 30 seconds.
- If you need to process an alert, press the alert row

- New alert appears
- Handling alert (acknowledged)
- Handled alert (hidden)

vivian.lai
Investment Properties

警報資料

2019-01-28 17:21:14

接收到警報 (4302)

位置: 九龍 > 開聯中心 > 12/F > 正門

裝置: 6400F_門 (裝置 ID 279)

檢測: SHIO Door

選擇回覆

10分鐘內到達

Fill in Remarks

0 / 50

跟進 完成處理

香港島 > 東華三院黃鳳翎紀念大樓 > LG2/F > 新街出路門(樓梯底)


- The alarm data interface explains the timing and source of the alarm in more detail.
- This interface can be also used for confirmation or processing actions.

Incident time and location



To handle the alert:

1. Check the information to make sure it is correct
2. Choose reply or reason.



3a. Press [SEND]
4a. The alert will change to "Acknowledged" status

3b. Press [BYPASS HANDLE]
4b. The alert will be directly changed to "Handled" status

Handle the "Acknowledged" alert:

5a. Choose reply / reason
6a. Press [SEND]
7a. The alert will change to the "Handled" status



- New alert appears
- Handling alert (acknowledged)
- Handled alert (hidden)

2486 - 開門 43 minutes ago
 香港島 > 東華三院黃鳳翎紀念大樓 > LG2/F > LG2/F 新街出路門(樓梯底)

2485 - 移動 43 minutes ago
 香港島 > 文咸東街64 號 > R/F > 天台兩邊出口

2483 - 開門 1 hour ago
 香港島 > 東華三院黃鳳翎紀念大樓 > LG2/F > LG2/F 新街出路門(樓梯底)

2482 - 檢測到移動 1 hour ago
 香港島 > 東慈商業中心 > G/F > 地下出路門 (近冷氣機房)

2481 - 開門 1 hour ago
 九龍 > 明德中心 > G/F > 大堂門

2480 - 開門 1 hour ago
 香港島 > 東華三院黃鳳翎紀念大樓 > LG2/F > LG2/F 新街出路門(樓梯底)

2479 - 開門 2 hours ago

Alert Detail

2019-01-14 09:38:26

Alert Issued (2487)

Location: 九龍 > 關聯中心 > 14/F > 正門

Device: 0320F_門 (Device ID 321)

Detected: SHIO Door

2019-01-14 10:19:30


Alert Acknowledged

By: Ben Liu (ben.liu@stone-road.net)

Reply: "在途中"

Reply

- 例行檢查
- 安裝測試
- 感應器誤報
- 正常巡樓



- New alert appears
- Handling alert (acknowledged)
- Handled alert (hidden)



Application settings and other information

